

## SALES SPECIFICATION SHEET

# FILTRASORB 600 AW 12X40

Granular Activated Carbon

Test	Specification		Calgon Carbon Test Method
	Min	Max	
IODINE NUMBER, mg/g	825	-	TM-4,ASTM D4607
WATER SOLUBLE ASH, wt%	-	0.1	TM-16
ABRASION NUMBER	80	-	TM-9,AWWA B604
TRACE CAPACITY NUMBER (TCN), mg/cc	15	-	TM-79,TM-85 (converted to TCN)
MOISTURE (AS PACKAGED), wt%	-	3	TM-1,ASTM D2867
12 US MESH [1.70 mm], wt%	-	5	TM-8,ASTM D2862
< 40 US MESH [0.425 mm] (PAN), wt%	-	4	TM-8,ASTM D2862

### Typical Properties:

This product complies with the requirements for activated carbon as defined by the Food Chemicals Codex (FCC) (Latest Edition) published by the U.S. Pharmacopeia.

This product is produced under supervision of the Islamic Food and Nutrition Council of America (IFANCA).

This product is prepared under the supervision of the Kashruth Division of the Orthodox Union and is Kosher.

Only products bearing the NSF Mark are Certified to NSF/ANSI/CAN 61 - Drinking Water System Components - Health Effects standard. Certified Products will bear the NSF Mark on packing or documentation shipped with the product.

**Calgon Carbon Corporation's activated carbon products are continuously being improved and changes may have taken place since this publication went to press. 12119-05/29/2024**



+1 800 422 7266 [calgoncarbon.com](http://calgoncarbon.com)

