



TECHNICAL GUIDE

Toilet Tank Diagnostics

This guide was inspired by discussions between Mike Urbans and Mike Heatwole on the "It's Your Water" podcast.

A toilet tank provides something a grab sample cannot: a visible record of what has been moving through the plumbing over time. Used alongside complete onsite testing, it can help identify sediment, mineral deposition, biological growth, escaped media, and installation problems.

1. Why the Toilet Tank Is a Useful Diagnostic Tool

Most field tests show the water condition at one moment. A toilet tank behaves more like a small settling basin. It repeatedly fills, stands, and partially empties. Fine particles settle, mineral deposits remain, and biological films may develop.

- Sediment collects in low-flow corners and along the bottom.
- Iron and manganese may leave persistent colored deposits.
- Organic growth may appear as slime, film, or rope-like material.
- Escaped resin or filter media may accumulate where it is easy to see.
- The condition of a rarely used tank may reflect months or years of water exposure.

Important: A toilet inspection does not replace testing. It adds visual evidence to the customer interview, field analysis, flow test, plumbing inspection, and equipment evaluation.

2. Professional Procedure

1. Ask permission before entering the bathroom or removing the tank lid.
2. Explain that the tank may provide useful information about the water and treatment equipment.
3. Ask the homeowner to remove fragile or sentimental objects from the tank when practical.
4. Place the porcelain lid on a folded towel or another protected surface—never directly on tile.
5. Photograph the tank only with the homeowner's permission.
6. Replace the lid and all items exactly as they were found.

3. Which Toilet Should Be Inspected?

The cleanest or most frequently used toilet is not always the most informative. When possible, inspect:

- A basement or utility-area toilet
- A guest bathroom
- An older fixture
- A toilet that is used infrequently
- A fixture located farthest from the treatment equipment

A pressure-assist toilet contains a sealed vessel and will not provide the same view as a conventional gravity tank. In that case, inspect another fixture or look for evidence elsewhere in the plumbing.

4. What to Look For

Observation	Typical Appearance	Possible Causes	Recommended Next Step
Sediment or Grit	Fine sand, grit, rust particles, or settled debris.	Well sediment, municipal main activity, corroding plumbing, exhausted or bypassed filters, or inadequate pretreatment.	Collect a sample if practical; inspect cartridges and housings; check pressure loss and flow; determine particle size and source.
Orange or Rust-Brown Deposits	Orange, red-brown, or rust-colored coating or sediment.	Iron entering the home, iron breakthrough, oxidation occurring after treatment, or an undersized or poorly maintained system.	Test iron onsite where practical; compare raw and treated water; inspect regeneration, oxidation, backwash, and service flow.
Dark Brown, Gray, or Black Deposits	Dark staining, black residue, or very dark settled material.	Manganese, manganese breakthrough, sulfur-related deposits, corrosion products, or carbon/media particles.	Test manganese and pH; identify whether particles smear, crush, or remain granular; inspect equipment and plumbing.
Slime or Gelatinous Growth	Brown, gray, white, clear, or rope-like growth; slippery deposits.	Iron-related, manganese-related, sulfur-related, or other biological activity.	Do not diagnose by appearance alone. Document the condition; review odor and fouling complaints; consider microbiological evaluation and disinfection strategy.
Surface Film or Sheen	A film on the water surface that separates when disturbed.	Biofilm or other organic material; occasionally cleaning products or tank additives.	Ask about tablets and cleaners first. Compare with another untreated tank before concluding that the film is biological.
Amber Spherical Beads	Small, round amber or tan beads.	Ion exchange resin escaping because of a broken distributor, damaged basket, internal valve problem, incorrect plumbing, or reverse flow.	Stop and inspect the treatment equipment promptly. Check plumbing direction, distributors, internals, and valve operation.
Black Granular Particles	Black particles that may smear, crush, or float.	Activated carbon, another dark filter medium, corrosion products, or manganese deposits.	Determine texture and uniformity; inspect treatment tank internals and plumbing; compare with the installed media.
White or Tan Granules	Light-colored chips or grains.	Calcite, corosex-type material, sand, scale, or other light-colored media.	Inspect neutralizer or filter internals; compare the sample with installed media; confirm service-flow direction.



5. Conditions That Can Mislead the Inspection

- Chlorine tablets, blue cleaners, and other tank additives can alter color, odor, film, and biological growth.
- A recently cleaned or replaced toilet may not show the home's historical water conditions.
- A pressure-assist tank cannot be evaluated like an open gravity tank.
- A single toilet may have a local plumbing issue that does not represent the entire home.
- Color alone is not a definitive identification of iron, manganese, bacteria, carbon, or corrosion products.

6. Installation Problems the Tank May Reveal

- Treatment equipment connected in the wrong flow direction
- Broken distributor tube or lower basket
- Internal control valve failure
- Media loss after service or backwash
- Inadequate backwash or incorrect drain-flow control
- Bypass leakage or incomplete treatment
- Treatment equipment undersized for actual service flow

7. How to Use the Findings

The inspection should guide additional testing—not become the final diagnosis. Photograph or document the observation, compare raw and treated water, verify equipment operation, and explain to the customer what is known, what is suspected, and what still needs to be confirmed.

8. Key Takeaways

- The toilet tank can act as a long-term visual record of water conditions.
- The most useful tank is often an older or infrequently used fixture.
- Sediment, staining, slime, film, resin, and filter media each point to different follow-up steps.
- Cleaning products and local fixture conditions can produce misleading evidence.
- A complete diagnosis combines visual inspection with onsite testing, equipment evaluation, and customer history.
- A consistent inspection procedure can reduce callbacks and strengthen customer confidence.



TOILET TANK DIAGNOSTIC FIELD FORM

Use with a complete onsite water analysis and equipment inspection

Customer / Site:		Date:	
Address:		Technician:	
Water Source:	☐ Private Well ☐ Municipal ☐ Other: _____	Fixture Location:	
Existing Treatment:		Last Service Date:	

Permission & Access	Tank Selection
☐ Permission obtained ☐ Decorative items removed safely ☐ Photo permission obtained ☐ Lid placed on protected surface	☐ Main bathroom ☐ Guest bathroom ☐ Basement / utility bathroom ☐ Infrequently used toilet ☐ Pressure-assist tank—alternate fixture inspected

Observed Condition	Present	Description / Location	Sample or Photo
Sediment / fine grit	☐ Yes ☐ No		☐ Photo ☐ Sample
Sand or coarse particles	☐ Yes ☐ No		☐ Photo ☐ Sample
Orange / rust-brown deposits	☐ Yes ☐ No		☐ Photo ☐ Sample
Dark brown / gray / black deposits	☐ Yes ☐ No		☐ Photo ☐ Sample
Slime / gelatinous growth	☐ Yes ☐ No		☐ Photo ☐ Sample
Surface film or sheen	☐ Yes ☐ No		☐ Photo ☐ Sample
Amber spherical resin beads	☐ Yes ☐ No		☐ Photo ☐ Sample
Black granular media	☐ Yes ☐ No		☐ Photo ☐ Sample
White / tan granular media	☐ Yes ☐ No		☐ Photo ☐ Sample
Unusual odor at tank	☐ Yes ☐ No		☐ Photo ☐ Sample



Field Test / System Check	Result	Notes
Raw Water pH		
Raw Water Iron		
Raw Water Manganese		
Service Flow / Well Flow		

Equipment Findings	☐ Flow direction verified ☐ Bypass checked ☐ Distributor / internals suspected ☐ Regeneration reviewed ☐ Backwash / drain flow reviewed ☐ Pressure loss checked
Likely Cause(s)	
Additional Testing Needed	☐ Treated-water comparison ☐ Bacteria evaluation ☐ Particle identification ☐ Plumbing inspection ☐ Other: _____

This form records field observations only. Visual appearance alone is not a definitive contaminant identification.



Source and Use Note

This technical guide was developed from the “Toilet Talk” discussion between Mike Urbans and Mike Heatwole for the It’s Your Water podcast, then expanded into a dealer-focused field reference. The guide is intended for professional education and troubleshooting support and is not a substitute for laboratory analysis, engineering review, or compliance guidance.